

MO-JO PLUMBING & SEPTIC SERVICES LLC.
LICENSE #CFC 1427913
(786) 346-5020

Service Rendered To:	Date:	Prepared By:	Job #	Valid Through
Buyer	03-26-26	Joseph	2026 1508	05-26-26
1508 SW 20th Ave				
Fort Lauderdale, FL				

Sewer Camera Results:
Please Note: We do not inspect tub or shower drain due to pipe size.
1. Main sewer pipe outside home is all PVC. (Great condition.)
2. Main sewer pipe inside home are all PVC pipes. (Great condition.)
3. Bathroom sewer pipes are all PVC pipes. (Great condition.)
4. Kitchen and laundry sewer pipes are all PVC. (Great condition.)
5. Vertical vent pipe is cast iron. (Functional condition)
Plumbing recommendation:
Studor vent needs to be install in the bathrooms to give more venting airflow. \$300.00