

**CERTIFICATION OF COMPLIANCE WITH PARKING LOT ILLUMINATION
STANDARDS IN CHAPTER 8C OF THE CODE OF MIAMI-DADE COUNTY**

Re: Case No. _____

Folio No. 6830 INDIAN CREEK DR

Property Address: 6830 INDIAN CREEK DR, MIAMI BEACH, FL

Bldg. No.: 1 Sq. Ft.: 53,342

Building Description: 10 story CUM construction with a flat roof used as residential condominiums

1. I am a Florida registered professional engineer or architect with an active license.
2. On Sept.24.2022, at 8:16pm, I measured the level of illumination in the parking lot(s) serving the above referenced building.
3. Maximum 10.9 foot candle per SF, Minimum 6.3 foot candle per SF, Minimum to Maximum ratio 10.9:6.3 foot candle 34.3 average per SF.
4. The level of illumination provided in the parking lot(s) Does the minimum standards for the occupancy classification of the building as established in section 8C-3 of the Code of Miami-Dade County.

 Digitally signed
by Balakrishnan
Vinayagar
Date: 2022.11.09
12:49:27 -05'00'

Signature and Seal of Architect or Engineer

Vinayagar M. Balakrishnan, M.S., P.E

FL. Reg. No: 63107